



- CONCRETE:**
- ALL CONCRETE WORK SHALL BE IN ACCORDANCE WITH THE "ACI STANDARD BUILDING CODE REQUIREMENT FOR STRUCTURAL CONCRETE" (ACI 318-99) (1) = 3000 PSI.
 - CONCRETE SHOULD BE PLACED IN THE FOOTING EXCAVATIONS AS SOON AS POSSIBLE BUT NOT LESS THAN 24 HOURS AFTER EXCAVATION TO MINIMIZE THE POSSIBILITY OF CURING OF DRILLED PIERS.
 - CLEAN TOPS OF PIERS AND BOTTOM OF GRADE BEAM TRENCHES THOROUGHLY PRIOR TO PLACEMENT OF CONCRETE IN THE GRADE BEAMS.
 - SEE ARCHITECTURAL DRAWINGS FOR FLOOR ELEVATIONS, SLOPES AND THE LOCATION OF FLOOR DEPRESSIONS.

- REINFORCING STEEL:**
- BARs - CONFORM TO ASTM A-615-GRADE 60, DOWELS AND STIRRUPS - GRADE 40.
 - WELDED WIRE FABRIC - CONFORM TO ASTM A-185 OR A-409, FURNISHED IN FLAT SHEETS AND MUST BE SUPPORTED ON CHAIRS SPACED 4'-0" O.C. MAXIMUM EACH WAY.
 - DETAILING - CONFORM TO ACI DETAILING MANUAL, 315-80.
 - REINFORCING STEEL COVERAGE:
 - FOOTINGS: 3" BOTTOM AND SIDES
 - GRADE BEAMS: 1 1/2" TOP, 3" SIDES (3" SIDES IF EARTH FORMED)
 - SLABS ON GRADE: 1 1/4" TOP
 - WALLS: 1 1/2"
 - LAP CONTINUOUS REINFORCING STEEL, 36 BAR DIAMETERS.
 - SLAB REINFORCEMENT SHALL BE SUPPORTED ON CHAIRS, @ 4'-0" MAXIMUM SQUARE GRID.
 - GRADE BEAM BOTTOM REINFORCEMENT SHALL BE SUPPORTED ON CHAIRS @ 6'-0" MAXIMUM SPACING.

| DATE | ISSUE HISTORY | | REVISIONS | |
|----------|---------------|------|-------------|--|
| | ISSUED FOR | DATE | DESCRIPTION | |
| 02/21/11 | PERMIT | | | |
| | CONSTRUCTION | | | |

| DAMICO'S RESTAURANT | | | |
|--|-------------------------|--|-------------|
| 2802 WHITE OAKS DRIVE, SUITE 500 HOUSTON, TEXAS 77007 | | | |
| DRAWN BY: DP | | | SHT.: |
| CHECKED BY: YY | PROJ. NO.: Y11-1000.001 | | S2.01 OF: 4 |