



410.72(C) Disconnecting Means. In indoor locations, disconnecting means shall be installed in readily accessible locations, including associated raceways and structures, fluorescent lighting fixtures, and other lighting fixtures, utilize double-ended lamps and contain ballast(s) that are readily accessible to the service point of the luminaire(s) that are supplied from multiple branch circuits. The disconnecting means shall be installed in a readily accessible location, including the ground-fault circuit interrupter (GFCI) receptacle, and shall be labeled to indicate the disconnecting means either internal or external to each luminaire. The disconnecting means shall be readily accessible to the occupant(s) of the premises from the source of supply at all times, including the grounded conductor if any.

SEE ATTACHED FIXTURES AND LIGHTING LEGEND.

ELECTRICAL NOTES:

1. POWER SUPPLY FOR EXIT SIGNS AND EMERGENCY LIGHTS SHALL BE PROVIDED BY THE PREMISES WIRING SYSTEM IN THE EVENT OF NORMAL POWER FAILURE TO MAINTAIN THE EXISTING EMERGENCY LIGHTING SYSTEM. EMERGENCY POWER-BATTERY BACK UP OR FROM AN ON-SITE EMERGENCY GENERATION SET TO ENSURE CONTINUED ILLUMINATION FOR A DURATION OF NOT LESS THAN 90 MINUTES.
2. BE-LEVEL SWITCHING (SECTION 805.2.1) BI-LEVEL SWITCHING USED FOR EACH AREA, LESS THAN 250 SF. THAT IS REQUIRED TO HAVE A MANUAL CONTROL SHALL BE SHALL ALSO ALLOW THE OCCUPANT TO REDUCE THE CONNECTED LIGHTING TO A UNIFORM ILLUMINATION PATTERN AT LEAST 50 PERCENT.

- EXCEPTIONS:
1. AREAS THAT HAVE ONLY 1 LUMINAIRE.
 2. AREAS THAT ARE CONTROLLED BY AN OCCUPANT-SENSING DEVICE.
 3. OFFICES, STORES, RESTROOMS, OR PUBLIC LOBBIES.
 4. GUEST ROOMS.

Kitchen hood luminaires shall be identified by the following conditions:

- (1) The luminaire shall be identified for use with commercial cooking hoods and installed such that the temperature limits of the materials used are not exceeded.
- (2) The luminaire shall be identified for use with commercial cooking hoods and excluded from the lamp and wiring compartment. Diffusers shall be resistant to thermal shock.
- (3) Parts of the luminaire exposed within the hood shall be corrosion resistant or protected against corrosion.
- (4) Wiring methods and materials supplying the luminaire(s) shall not be exposed within the cooking hood.