


1 ELECTRICAL LIGHTING PLAN - LOWER LEVEL
SCALE: 1/4" = 1'-0"

ELECTRICAL KEYED NOTES:

- (1) REFER TO SHEET E2.01 FOR COOLER LIGHTING REQUIRED.
- (2) HOOD LIGHT SWITCH PROVIDED BY HOOD MANUFACTURER.
- (3) MOUNT EMERGENCY LIGHTING UNIT AT 6' BELOW FINISHED CEILING.
- (4) PROVIDE LEVITON #94208 ARCHITECTURAL LIGHTING CONTROL SYSTEM FOR DIMMING AND SCENE CONTROL OF MAIN DINING, BAR, AND LOBBY LIGHTING CIRCUITS. INTEGRATED SYSTEMICAL TIME CLOCK FOR AUTO SHUT-OFF DURING TO CORONANT PROGRAMMING OF SYSTEM. REFER TO DETAIL #2 ON SHEET E3.2 FOR MORE INFORMATION.
- (5) TO DIMMING CONTROL SYSTEM. REFER TO DETAIL #2 ON SHEET E3.2 FOR MORE INFORMATION.
- (6) REFER TO DETAIL 1 ON SHEET E2.00 FOR LIGHTING IN THIS AREA.



ISSUE
11-30-10
ISSUED FOR PERMIT

HARRELL
ARCHITECTS, LP

9275 KOWI Fwy., #200
Houston, Texas 77024
tel: 713.722.7071
fax: 713.722.7072

CONSULTANTS
HQS SITE & ASSOCIATES
MEP Engineers




PROJECT NAME
GUADALUPANA
RESTAURANT

PROJECT ADDRESS
20 WATERWAY
THE WOODLANDS, TEXAS

PROJECT NUMBER
SHEET NAME
**ELECTRICAL
LIGHTING PLAN**
SHEET NUMBER

E1.00



Holbe & Associates, Inc.
Consulting Engineers - Texas Reg. 15843
Houston, Texas 77071 (713) 962-1371
www.holbe.com