



ISSUE
 09-10-10 ISSUED FOR PERMIT
 10-08-10 DBR REVIEW COMMENTS
 11-02-10 ISSUED FOR CONSTRUCTION

ELECTRICAL KEYED NOTES:
 (FOR SHEET E2.02)

- 1 NEW 277/480V, 3Ø, 4W PANELBOARD HA. REFER TO SHEET E4.00 FOR PANEL SCHEDULE INFORMATION.
- 2 NEW 120/208V, 3Ø, 4W PANELBOARD LA. REFER TO SHEET E4.00 FOR PANEL SCHEDULE INFORMATION.
- 3 NEW 120/208V, 3Ø, 4W PANELBOARD CA. REFER TO SHEET E4.00 FOR PANEL SCHEDULE INFORMATION.
- 4 480V: 120/208V, 3Ø, 4W (112.5KVA) TRANSFORMER TLA. FRONT OF XFMR SHALL FACE PLAN NORTH AND HAVE A MINIMUM OF 3'-0" CLEARANCE PER N.E.C.
- 5 4'-0" X 3/4" THICK FIRE RETARDANT PLYWOOD TELEPHONE BACKBOARD. UTILIZE SHELL BUILDING STUB AND EXTEND (1) 1/2" C. FROM BUILDING TELEPHONE NETWORK DEMARCATION POINT. FIELD VERIFY EXACT LOCATION OF TELEPHONE COMPANY CABINET.
- 6 J-BOX FOR ALARM EQUIPMENT.
- 7 J-BOX FOR SECURITY EQUIPMENT.
- 8 200A/3P/200AF DISCONNECT SWITCH FOR PANEL LA IN KITCHEN BELOW.
- 9 J-BOX FOR MOTORIZED DAMPERS. COORDINATE EXACT LOCATION WITH MECHANICAL CONTRACTOR.

NOTE: REFER TO SHEET E2.03
 DETAIL #3 FOR TENANT SERVICE
 DISCONNECT AND METER LOCATION.



1 ELECTRICAL FLOOR PLAN - MEZZANINE
 SCALE: 1/4" = 1'-0"

HARRELL
 ARCHITECTS, LP

9575 Katy Frey., #200
 Houston, Texas 77024
 tel: 713.722.7071
 fax: 713.722.7072

CONSULTANTS
HOLSTE & ASSOCIATES
 MEP Engineers

Holste & Associates, Inc.
 Consulting Engineers - Texas Reg. P-5443
 4671 Southwest Frey., Suite 850
 Houston, Texas 77024 (713) 955-1351
 www.holstemep.com

PROJECT NAME
LUCA & LEONARDO RESTAURANT



PROJECT ADDRESS
 20 WATERWAY
 THE WOODLANDS, TEXAS

PROJECT NUMBER
 10018
 SHEET NAME
ELECTRICAL MEZZANINE PLAN
 SHEET NUMBER

E2.02