







ISSUE
 01-12-12 ISSUED FOR REVIEW
 01-25-12 ISSUED FOR PERMIT
 02-16-12 ISSUED FOR BIDDING

-  PATH OF EGRESS = 42" WIDE
-  EXIT
-  FEC FIRE EXTINGUISHER CABINET
-  FE WALL-MOUNTED FIRE EXTINGUISHER

LEGEND

1. REFER TO GENERAL INFORMATION SHEET A0.0 FOR OCCUPANT LOAD AND EGRESS CALCULATIONS.
2. FIRE EXTINGUISHERS: COMPLY WITH PRODUCT REQUIREMENTS OF NFPA 10 AND APPLICABLE CODES, WHICHEVER IS MORE STRINGENT.
 1. TYPE FE: DRY CHEMICAL TYPE FIRE EXTINGUISHERS: CAST STEEL TANK, WITH PRESSURE GAGE, CLASS A,B,C, SIZE 10.
3. FIRE EXTINGUISHER CABINETS (FEC).
 1. BOX: SEMI- RECESSED 20 GAGE COLD ROLLED STEEL WITH WHITE BAKED ENAMEL FINISH.
 2. TRIM: FLAT TRIM 1,3/4 INCHES WIDE BY 5/16 INCH (AT GYPSUM BOARD, MASONRY AND TILE SURFACES).
 3. DOOR: SOLID PANEL, 20 GAGE COLD ROLLED STEEL WITH WHITE BAKED ENAMEL FINISH, MANUFACTURER'S STANDARD LATCH, CONTINUOUS (PIANO TYPE) HINGE, VERTICAL LETTERING READING "FIRE EXTINGUISHER".

GENERAL LIFE SAFETY NOTES



9575 Katy Frwy., #200
 Houston, Texas 77024
 tel: 713.722.7071
 fax: 713.722.7072

CONSULTANTS
 Holste & Associates, Inc.
 MEP Engineers

PROJECT NAME

Maharaja Bhog

PROJECT ADDRESS
 8338 Southwest Freeway
 Houston, Texas 77074

PROJECT NUMBER
 11078
 SHEET NAME
FLOOR LIFE SAFETY PLAN
 SHEET NUMBER

A2.4

